



**IONA McGREGOR FIRE DISTRICT**  
**FIRE PREVENTION**  
15961 WINKLER ROAD  
FORT MYERS, FLORIDA 33908



PREVENTION OFFICE: (239) 425-9336  
FAX: (239) 433-2673

## **Underground Fire Line Inspection Schedule**

1. Check for permit, red stamped plan set, and underground contractor's license.
2. Check piping materials requirements.
3. Open ditch inspection for: Elbows, bell restraints, T's, couplers, and thrust blocks at all 90 degree joints.
4. Install metallic tracer tape in ditch.
5. Check/install electrical conduit for tamper switches. Burial depth a minimum of 18".
6. All non-stainless hardware shall be coated with anti-corrosion material.
7. Hydro test from B.F.P.'s to building stub @ 200 psi for a minimum of 2 hours.
8. Full-bore line flush from B.F.P.'s to building stub before any sprinkler piping is connected.
9. Hydro test from B.F.P.'s to pump house.
10. Full-bore line flush from B.F.P.'s to pump house.
11. Hydro test from pump house to building stub.
12. Full-bore line flush from pump house to building stub.