

Underground fire line inspection

## IONA McGREGOR FIRE DISTRICT FIRE PREVENTION

15961 WINKLER ROAD FORT MYERS, FLORIDA 33908



PREVENTION OFFICE: (239) 425-9336 FAX: (239) 433-2673

Checklist for inspections – Make sure these inspections are scheduled at least 5 business days prior to the inspection being needed. Fax request page below.

chwigiown in a map with
Rough and hydro on sprinkler piping
Final on sprinkler system
Firewall inspection – first layer
Firewall inspection – second layer
Firewall/Firelid – Stencil fire wall "Fire Wall – (1,2,3, or 4) hour rating and UL design number.
Example UL419.
Fire stopping inspection – Have stopping book with UL cut sheets at site
Rough wire inspection for fire alarm
Duct detector/Air velocity test
Final inspection of fire alarm
Final inspection of fire alarm monitoring
Flammable liquid storage tank inspection
Hood and suppression system (for cooking)
Propane gas line inspection under ground (unburied) pipe hydro.
Propane gas above ground inspection.
Natural gas above ground inspection
Final inspection and pump performance of fire pump to be completed with pump manufacturer representative
Final inspection of elevator
Final inspection of generator
Final inspection of fire dampers after test and balance of HVAC
Final building inspection

Inspection Request Form Fax five days before requested date of inspection

Contractor:

Contact Numbers:

Fax Number:

Project Name:

Address:

Permit Number:

Type of Inspection
Requested: Date and Time

Inspection Request Form Fax five days before requested date of inspection

Contractor:

Contact Numbers:

Fax Number:

Project Name:

Address:

Permit Number:

Type of Inspection
Requested: Date and Time