



IONA McGREGOR FIRE DISTRICT

FIRE PREVENTION

15961 WINKLER ROAD
FORT MYERS, FLORIDA 33908

PREVENTION OFFICE: (239) 425-9336
FAX: (239) 433-2673



General

Plans/Permits
Fees Paid
Fire Extinguishers
Knox Box – Master, duct, FACP, sprinkler locks
EVAC Gate controller in

Clubhouse
Pool phone at pool

Signage

Fire Lane
Address Number
Street Signs
Unit Numbers – Front
Unit Numbers – Back
Unit Numbers – Electrical Meters
Unit Numbers – HVAC Control
Unit Numbers – Gas Control
Electrical rooms labeled “Electrical”
Siren Activated Gate – “YELP”
Stairwell signage
Fire Walls Marked

Hazardous Rooms

Marked
Threshold Installed
Metal shelves w/lips

Locks

Thumb turns
Panic hardware w/o disabler
Delayed egress 15 seconds
Delayed egress marked

Damper

Damper access openings
Damper access openings marked
Damper log in FACP room

Fire Pump

Weekly Pump Runs
Documented Pump Runs on Log
Semi Annual Inspections
Annual Pump Performance Tests

Sprinkler System

Calc plate on riser – stamped
Standpipe marked wet/dry on each floor

Spare head and box

FDC sign posted
OSY/Backflow labeled
Riser door labeled
Quarterly Inspection Agreement

Marinas

Dock Number in 12”
Dock Slip # in 3-4” tall.
Standpipes shall be identified with weatherproof signage.

Fire Proofing

UL Approved method
Fire Walls stenciled with rating

Hood Suppression

Nozzle distances & What nozzles
Links
Balloon or Dry cylinder for Badger
Nozzle foils / caps
Flow Points
Gas/Electric Shut Down
Hooked into fire alarm
Make up air shut down
Ventilation fan
System tagged
Appliance locations marked
Pull stations labeled

Hood

Penetrations
Combustible clearance
Ductwork
Cleanouts

Final Paperwork

AG and UG sprinkler report
Elevator Inspection
Certificate of Completion for fire alarm
Signed sprinkler agreement

AG & UG Flammable Tanks

1/8/07