



IONA MCGREGGOR FIRE DISTRICT
6061 SOUTH POINTE BLVD
FORT MYERS, FLORIDA 33919

MAIN OFFICE: (239) 433-0660
PREVENTION OFFICE: (239) 425-9336
www.ionafire.com



GRILL USE & LP STORAGE REQUIREMENTS

The following requirements are cited from the *Florida Fire Prevention Code, 7th ed.*
This is the current standard in which our office is responsible to enforce.

NFPA 1 Fire Code

10.10.6 Cooking Equipment. 10.10.6.1 For other than one- and two-family dwellings, no hibachi, grill, or other similar devices used for cooking, heating, or any other purpose shall be used or kindled on any balcony, under any overhanging portion, or within 10 ft of any structure.

10.10.6.1.1 Listed electric portable, tabletop grills, not to exceed 200 square inches of cooking surface, or other similar apparatus shall be permitted.

10.10.6.2 For other than one-and two-family dwellings, no hibachi, grill, or other similar devices used for cooking shall be stored on a balcony.

10.18.7 Fueled Equipment. Fueled equipment, including but not limited to motorcycles, mopeds, lawn-care equipment, and portable cooking equipment, shall not be stored, operated, or repaired within a building except under one of the following conditions: (1) The building or room has been constructed for such use in accordance with the building code. (2) The use is allowed by other provisions of this Code.

69.5.3.5 (LP) Storage Within Residential Buildings. Storage of cylinders within a residential building, including the basement or any storage area in a common basement of a multiple-family building and attached or detached garages, shall be limited to cylinders each with a maximum water capacity of 2.7 lb (1.2 kg) and shall not exceed 5.4 lb (2.4 kg) aggregate water capacity per each living space unit.

Please email FirePrevention@ionafire.com with any questions.

Respectfully,

Jackielou Mozes
Fire Marshal